

MANUAL FOR WIRELESS INTERCONNECTION STROBE SIREN ALARM

4、 Tamper alarm: tamper switch off, the product will enter the alarm state, has been flashing bright LED, buzzer has been ringing; until tamper closed closing before resuming normal operation.

5、 the low pressure alarm: the supply voltage is lower than 9.2V, the product will enter the alarm state, bright LED flash one time interval 5S, 5S interval buzzer flash 1 times.

Note: The supply voltage must $\leq 12V$, otherwise it will damage the product.